



NOTES

1. ANODE SHALL BE PLACED AT LEAST 1.0 m AWAY FROM THE FITTING AND BELOW OR LEVEL WITH WATERMAIN. MINIMUM DISTANCE BETWEEN ANODES SHALL BE 1.0 m.
2. ALL BONDING AND ANODE CABLE CONNECTIONS SHALL BE THERMITE WELDED. ALL THERMITE WELD CONNECTIONS SHALL BE COATED WITH AN APPROVED COATING MATERIAL.
3. BONDING CABLE SHALL BE NO. 6, SEVEN STRAND COATED COPPER WIRE, CADWELDED TO FITTINGS.
4. ANODES SHALL BE PLACED BELOW OR LEVEL WITH WATERMAIN.
5. MAGNESIUM ANODE CABLES SHALL BE BLUE AND ZINC ANODE CABLES SHALL BE WHITE.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



**CATHODIC PROTECTION / BONDING CABLE
FOR EXISTING FERROUS WATERMAIN SYSTEMS**

DWG. DATE:	1991 11
REVISION NO.:	6
REV. DATE:	2013 04
SCALE:	N.T.S.

S-201.031